

**ORDINANCE #2007-6**

**AN ORDINANCE AMENDING THE TOWN OF PONCHA SPRINGS  
STANDARD DESIGN CRITERIA AND STANDARD CONSTRUCTION  
REQUIREMENTS AND LAND USE CODE**

**WHEREAS**, the Town of Poncha Springs Maintenance and Utilities Committee recommends the Poncha Springs Board of Trustees adopt the following changes to the Town of Poncha Springs “Standard Design Criteria and Standard Construction Requirements;” and

**WHEREAS**, water meters located in driveways pose special problems for maintenance of the meters.

**NOW THEREFORE BE IT ORDAINED**, that section 01010, Water Line Design Criteria, of the Town of Poncha Springs “Standard Design Criteria and Standard Construction Requirements” is hereby amended as follows:

1.4 SERVICE LINES

D. Meter pits located beneath asphalt, ~~or concrete~~ **or in driveways** shall be constructed from standard precast concrete **4’ diameter** manhole sections. Meter pits located with landscaped areas shall be constructed of bituminous fibers.

PASSED AND APPROVED, this **9th** day of **July 2007**, by the Poncha Springs Board of Trustees.

/s/ \_\_\_\_\_  
Mark F. Thonhoff, Mayor

ATTEST:

/s/ \_\_\_\_\_  
Diana K. Heeney  
CMC/Treasurer

~~Strikethrough~~ = deleted text

**Bold** = added text